

PAUL STRESSING ASSOCIATES, INC.

14517 MAIN STREET
ALACHUA, FLA 32415

E-MAIL paa@paulstressingassociates.com
TELEPHONE (386) 462-6407 FAX (386) 462-6409
REGISTRATION NO. AR0013985 CA NO. AA0003377

| | |
|-------------|----------|
| DRAWN BY: | JMA/CSH |
| DATE: | 02/17/11 |
| PROJECT NO: | |

- A. FLORIDA BUILDING CODE, 2007 (OR LATEST EDITION)
- B. STANDARD PLUMBING CODE, 2007 (OR LATEST EDITION)
- C. NATIONAL ELECTRICAL CODE, 2007 (OR LATEST EDITION)
- D. STANDARD MECHANICAL CODE, 2007 (OR LATEST EDITION)
- E. STANDARD GAS CODE, 2007 (OR LATEST EDITION)
- F. FLORIDA FIRE PREVENTION CODE, 2007 (OR LATEST EDITION)
- G. NFPA LIFE SAFETY CODE, 2009 (OR MOST RECENT REVISION), NFPA 101 AND OTHER NFPA CODES AS APPLICABLE.
- H. ANSI A117J SPECIFICATIONS FOR MAKING BUILDING AND FACILITIES ACCESSIBLE TO AND USEABLE BY PHYSICALLY HANDICAPPED PEOPLE, 1993 (OR LATEST EDITION).

1. PROVIDE ALL FLORIDA PRODUCT CERTIFICATIONS FOR EXTERIOR CLADDING & ITEMS EXPOSED TO THE ENVIRONMENT AS REQUIRED BY THE LATEST EDITION OF THE FLORIDA BUILDING CODE.
2. COORD ALL NECESSARY WORK W/ INTERFACING TRADES, INCLUDING BUT NOT LIMITED TO, MECH PENETRATIONS, DOORS & INTERIOR VIEW WINDOWS, SUBCONTRACTORS TO PROVIDE THEMSELVES ACCESS TO THE WORK AREA. IF A FIRE RATING ITEM IS OVERLOOKED OR AN ACCESS PANEL IS NOT TO BE GAIN ACCESS TO THE BUILDING'S UTILITIES, THEN THE SUBCONTRACTOR WHO IS EXPECTED TO BE AN EXPERT IN THEIR FIELD MUST BE RESPONSIBLE FOR THE VIOLATION OF THEIR DISCIPLINE IS TO PROVIDE A COMPLETE SYSTEM IN FULL COMPLIANCE W/ ALL APPLICABLE CODES INCLUDING ANY & ALL MECH INCIDENTALS FOR A COMPLETE INSTALLATION OF THE WORK.
3. ALL INTERIOR AND EXTERIOR MASONRY JOINTS TO BE RAKED & TOOLEY 3/8".
4. ALL MASONRY HEAD & BED MORTAR JOINTS TO BE RAKED & TOOLEY 3/8". DEPTH: CONTRACTOR TO CHECK THEM DAILY & IF NECESSARY HAVE THEM REPAIRED OR REPLACED. DAMAGED MASONRY JOINTS TO BE USED ONLY IN MECH, ELECT OR STORAGE ROOMS
5. ALL EXTERIOR WALL & CEILING OUTSIDE CORNERS AT UPPIRES' SHOWERS BUILDING ARE TO BE RADIOUSD.
6. DO NOT LOCATE ELECTRICAL DEVICES BACK TO BACK, PROVIDE POSITIVE INSULATE BACKSIDE OF ALL WALL BOARD.
7. PROVIDE MOISTURE RESISTANT BACKBOARD AT ALL FRAMED CERAMIC TILE WALL AREAS (SEE ROOM FINISH SCHEDULES AND INTERIOR ELEVATIONS).
8. TOILET TO INCLUDE ALL NECESSARY ITEMS AS REQD AT ALL CEILING & WALL MOUNTED EQUIPMENT INCLUDING BUT NOT LIMITED TO TOILET PARTITION PILASTERS, GRAB BARS, TOILET PAPER DISPENSERS, PAPER TOWEL DISPENSERS, SOAP DISPENSERS, ETC., FOR A COMPLETE AND SECURED INSTALLATION.

[illegible]

WALL TYPE (INTERIOR WALL) 7

| | | | |
|--|------------------------------------|--|--|
| | BATT INSULATION | | FINISH WOOD (IN SECTION) |
| | RIGID INSULATION | | PLYWOOD (IN SECTION) |
| | BRICK VENEER | | WOOD FRAMING (IN SECTION) |
| | CONCRETE BLOCK (w/ FILLED CELL) | | POURED IN PLACE CONC. (IN SECTION) |
| | EARTH (UNDISTURBED) | | STEEL (IN SECTION) |
| | EARTH (DISTURBED & COMPACTED) | | VENEER PLASTER BASE SYSTEM |
| | EXISTING CONSTRUCTION | | STEP DOWN IN MATERIAL |

PRODUCT COMPLIANCE: ALL PRODUCTS USED ON THIS PROJECT TO MEET OR EXCEED THE FLORIDA PRODUCT APPROVAL REQUIREMENTS AND CERTIFICATION FOR ALL MAJOR EXTERIOR BUILDING COMPONENTS (ROOF, WINDOWS, DOORS, ETC.) CONTRACTOR TO PROVIDE CERTIFICATION AND TEST DATA WITH SHOP DRAWING SUBMITTALS FOR REVIEW BY ARCHITECT AND OWNER. IT IS THE CONTRACTOR'S SOLE RESPONSIBILITY TO VERIFY PRODUCT APPROVAL OF INTERESTED VENDORS AT TIME OF BIDDING.

7'-1" MIN.

5'-0" MIN.

1'-6"

3'-6"

6" MAX.

36" MIN.

2'-6"

1'-3" LAV.

4" REQ'D BY THE SFGC BROWARD ED. 46(3), (a)(4) OR THE SFGC DADE EDITION 46(3) (a)(4)

1'-7" MIN.

1'-5" MIN.

2'-8" MIN. FBC 11.4.13.5

4'-11" MIN.

3'-6"

4'-0"

5'-0" MIN.

4'-11" MIN.

3'-6"

4'-0"

1'-7" MIN.

1'-5" MIN.

2'-8" MIN. FBC 11.4.13.5

OPTIONAL DOOR LOCATION

ASSUMPTIONS / REQUIREMENTS

1. ACCESSIBLE WAC DEPTH IS 30" & WAC IS FLOOR MOUNTED.
2. CONTROLS FOR FLUSH VALVES SHALL BE MOUNTED ON THE WAC SIDE OF THE WAC AREAS (FACED 46(3)).