




LIGHTING FIXTURE SCHEDULE

TYPE	MANUFACTURER	CATALOG NUMBER	LAMP		VOLTS	MTG. HEIGHT	REMARKS
			SIZE	QUAN.			
A	LUMAX	LG232-24-EP09-FB-RS-EA	32W T8	2	120	CEILING	2X4 FLUORESCENT LENSED/LOWERED TROFFER
B	COLUMBIA	CS4-232-EBU-F028841	32W T8	1	120	CEILING	1X4 SURFACE MOUNT FLUORESCENT (NOTE 8)
C	PRESCLUTE	LF6CH13ZEB-6C7HP-B24-LP32THKOS	32W	1	120	CEILING	DOWNLIGHT/ RECESSED CAN LIGHT
D	W.F. HARRIS	300-BY-INC.	100W	1	120	7'-4" AFG	EXTERIOR WALPACK W/ PHOTOCELL
F	HUNTER	MODEL 20803-LOW PROFILE III-52"	-	1	120	CEILING	CEILING FAN W/ REMOTE
M	HUBBELL AUTOMATION	OMNI07500-LVPP	-	-	-	CEILING	OCCUPANCY SENSOR
EX	COMPASS	CSXWREB3	WITH UNIT	1	120	WALL/CEILING	EXIT LIGHT
EM	COMPASS	ECSELI	WITH UNIT	1	120	WALL/CEILING	EMERGENCY LIGHT
EXEM	COMPASS	SXWRS3	WITH UNIT	1	120	WALL/CEILING	EMERGENCY/EXIT COMBO LIGHT
Ⓜ	HUBBELL AUTOMATION	OMNI07000-LVPP	-	-	-	CEILING	OCCUPANCY SENSOR -LARGE OFFICES
-	HUBBELL AUTOMATION	LHMTSIW	-	-	-	WALL	OCCUPANCY SENSOR -WALL MOUNTED

- NOTES:
- WHERE AVAILABLE, ALL FIXTURES TO BE INSTALLED WITH ELECTRONIC BALLASTS.
 - FOR LIGHT FIXTURE INFORMATION, REFER TO: JEFF SHIELDS, WFL-JAX, INC., 6500 PHILIPS HWY., SUITE 9/10, JACKSONVILLE, FL 32216 (904) 566-8011
 - ALL EXCESS LIGHTING SHALL BE FOR COMPLIANCE.
 - ALL EXCESS LIGHTING SHALL BE FOR COMPLIANCE.
 - IF DEVIATING FROM FIXTURE SCHEDULE, E.O. SHALL PROVIDE EXTERIOR PHOTOMETRICS.
 - PROVIDE 1/2" CONDUIT FOR CONTROL WIRE TO INTERLOCK DUCT DETECTORS
 - TO FUEL TANK, GAS VALVE. PROVIDE SOLENOID VALVE. POWER, CIRCUIT M2-33.
 - MOUNT ABOVE DOOR.



r. michael
writearchitect p.a.
12502 s.e. 10th avenue, north 34471pc, 3352
306-5889 f: (352) 386-8689w 0007080

project name:

Range Maintenance
Administration Expansion
FOR:
Department of Military Affairs
Stark, Florida

project number: 211033

consultants:

William Henry, P.E.
License No. 50750
LENN ENGINEERING, INC.
Cert. of Regn. No. 9734
2644 Seneca Drive
Jacksonville, FL 32259 Phone 904-571-3008

seal / signature:

William Henry, P.E.
Florida P.E. Number 50750

r. michael write, architect

revision item: date:

drawn by: SAA

checked by: WH

computer file name:

Issue date: AUGUST 5, 2011

sheet title:

POWER AND
LIGHTING PLANS

drawing scale:

SCALE AS NOTED

sheet number: