


SANITARY RISER DIAGRAM

SCALE: NOT TO SCALE

1
P5.1

① INTERLOCK GAS SOLENOID VALVE WITH DUCT SMOKE DETECTORS. UPON DETECTION OF SMOKE AT ANY AIR HANDLER THE GAS VALVE SHALL BE DE-ENERGIZED AND CLOSE 100%. SOLENOID VALVE SHALL BE UL AND AGA APPROVED, 120 VOLT, NORMALLY CLOSED LP GAS VALVE BY "ASCO" #804337 WITH PROOF OF CLOSURE INDICATOR, 120 VOLT, 59.5 WATTS ENCLOSURE. SHALL BE WATER TIGHT AND EXPLOSION PROOF.




TOTAL DEVELOPED LENGTH = 175 FEET

GAS RISER DIAGRAM

SCALE: NOT TO SCALE


2
P5.1



DOMESTIC WATER RISER DIAGRAM

SCALE: NOT TO SCALE

4
P5.1



TRAP PRIMER DETAIL

SCALE: NOT TO SCALE

3
P5.1

project name:

Range Maintenance
Administration Expansion

FOR:
Department of Military Affairs
Starke, Fl.

project number: 209035

consultants:

Estrella Engineering Incorporated
1555 Kingsley Ave., Suite 302 * Orange Park, Florida 32073
(904) 269-7880 * Mail@Estrella-Engineering.com
Certificate of Authorization - EB 5020

seal / signature:

Larry Estrella, PE
License No.36242

revision item:

date:

drawn by:

RE

checked by:

LE

computer file name:

issue date:

08/18/2011

sheet title:

PLUMBING RISERS

drawing scale:

SCALE AS NOTED

sheet number: