

in clearly and easily understandable form.. Data shall show all serial numbers of each piece of equipment, complete list of placement parts, motor ratings, and actual loads.

- D. It is the intent of this catalog, operation and maintenance data to provide the Owner with complete instructions on the proper operation and use, lubrication and periodic maintenance, together with the source of replacement parts and service, for the items of equipment covered.

1.12 CONTRACTOR COORDINATION

- A. The Electrical Contractor shall furnish, set and wire all disconnect devices and starters as required for all equipment except for those items furnished with integral disconnect devices and/or starters.
- B. Furnish detailed information to the Electrical Contractor on power wiring requirements for all mechanical and plumbing equipment actually purchased as soon as practical. This shall include all diagrams and instructions necessary for the Electrical Contractor to make connections properly. If equipment actually purchased requires larger electrical service than equipment scheduled, arrange and pay for required electrical service charge.
- C. Provide all air conditioning control devices, including thermostats, and complete all control wiring, including final connections.
- D. Coordinate location of equipment, piping, and duct work with other trades to maintain clearance for equipment maintenance, prevent interference with duct and piping runs, and to prevent ducts and piping from being installed over electrical panels. If interference develops, the Architect will decide which equipment, conduit, duct, piping, etc., must be relocated regardless of installation order. Take responsibility for relocating the work of your trade, if so ordered, including all associated costs.
- E. Within 30 days following award of the Contract, report to the Architect, in writing, all real or potential errors, ambiguities and/or conflicts on the Mechanical and Plumbing Work or between the trades and obtain an agreement with the Architect on a solution. Those reported after 30 days, except as a result of unforeseen circumstances, shall be resolved at the discretion of the Architect. Report conflicts resulting from the progress of Work to the Architect immediately or accept the expense of corrective work caused by failure to report such a conflict.

1.13 CHANGES

- A. Do not make any changes in design without the written approval of the Engineer. Changes in design means an change which may affect the capacity, reliability, operation or safety of the systems or any parts thereof, including changes which may be required to conform to local regulations or codes.

1.14 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than three years of documented experience.