

graphite and linseed oil. Ensure clearance at cleanout for rodding of drainage system.

- C. Encase exterior cleanouts in concrete or cast iron access box (paved areas) or pvc access box (unpaved areas) flush with grade.
- D. Install floor cleanouts at elevation to accommodate finished floor.
- E. Install approved potable water protection devices on plumbing lines where contamination of domestic water may occur; on boiler feed water lines, janitor rooms, fire sprinkler systems, premise isolation, irrigation systems, flush valves, interior and exterior hose bibs.
- F. Pipe relief from backflow preventer to nearest drain.
- G. Install water hammer arrestors complete with accessible isolation valves on hot and cold water supply piping to lavatories, flush valves, sinks, washing machine outlets, dental equipment connections, makeup water connections and refrigerator outlets in accordance with PDI WH 201 guidelines as outlined in drawings.